

CERES WWTW														
PARAMETERS	GENERAL LIMITS	Jul-22	Aug-22	Sep-22	Oct-22	Nov-22	Dec-22	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	AVE 12 MONTHS
MICROBIOLOGICAL														
Faecal Colif0rms (org/100ml)	< 1000	<1	<1	16	40	866	>2419	365	345	36	145	<1	11	
COMPLIANCE PER MONTH		100	100	100	100	100	0	100	100	100	100	100	100	
AVERAGE COMPLIANCE														91,67
PHYSICAL														
pH	5.5 - 9.5	8,3	8,2	8,5	8	8,41	8,9	8,4	8,3	8,7	8,2	8,18	8,1	
Conductivity (at 25°C) (mS/m)	150	80	93,9	109	118	116	119	133	115	97,4	117	111	95,4	
TSS (mg/l)	25	8	<4	21	15	19	22	22	31	25	59	18	27	
COMPLIANCE PER MONTH		100	100	100	100	100	100	100	67	100	67	100	67	
AVERAGE COMPLIANCE														91,75
CHEMICAL														
COD (mg/l) - Unfiltered	75	49,4	28,8	69,1	52,8	59,9	124	99,2	72,2	69	162	36,4	45,3	
Ammonia Nitrogen as N (mg/l)	6	0,23	1,1	0,11	0,3	<0,2	20,5	9,4	11,1	3,1	25,7	22,6	4,3	
Nitrate Nitrogen as N (mg/l)	15	<0,2	<0,2	0,95	0,7	0,2	0,2	0,78	<0,2	0,5	<0,2	<0,2	0,35	
Ortho Phosphate as P (mg/l)	10	2,2	3,3	1,4	8,6	5,8	2,3	7,2	6,1	3,2	4	0,83	3,3	
COMPLIANCE PER MONTH		100	100	100	100	100	50	50	75	100	50	75	100	
AVERAGE COMPLIANCE														83,33
OVERALL		100	100	100	100	100	50	83	81	100	72	92	89	
OVERALL COMPLIANCE FOR 2022/2023														89