

WOLSELEY WWTW														
PARAMETERS	GENERAL LIMITS	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	AVE 12 MONTHS
MICROBIOLOGICAL														
Faecal Colif0rms (org/100ml)	< 1000	17	9	12	770	28	<1	28	11	<1	8	17	<1	
COMPLIANCE PER MONTH		100	100	100	100	100	100	100	100	100	100	100	100	
AVERAGE COMPLIANCE														100,00
PHYSICAL														
pH	5.5 - 9.5	7	7,1	7,6	7,3	7,5	7,8	7,8	7,3	7,4	7,39	7,2	7,2	
Conductivity (at 25°C) (mS/m)	150	78	86,9	109	84,5	114	129	109	113	110	110	117	134	
TSS (mg/l)	25	9	16	14	22	115	8	17	41	188	77	17	24	
COMPLIANCE PER MONTH		100	100	100	100	67	100	100	67	67	67	100	100	
AVERAGE COMPLIANCE														89,00
CHEMICAL														
COD (mg/l)	75	68	50	71,9	42,2	74,1	71,1	48	107	236	208	116	57,1	
Ammonia Nitrogen as N (mg/l)	6	2,2	5	9,2	4	0,32	19,3	29,7	21,7	58,9	34	42	31,8	
Nitrate Nitrogen as N (mg/l)	15	4,9	3,2	0,31	2,4	0,95	0,51	0,42	<0,2	<0,2	<0,2	<0,2	<0,2	
Ortho Phosphate as P (mg/l)	10	2,5	4,6	3,3	2,2	3,4	5,5	8,5	5,2	4,2	<0,2	3,6	6,6	
COMPLIANCE PER MONTH		100	100	75	100	100	75	75	50	50	50	50	75	
AVERAGE COMPLIANCE														75,00
OVERALL		100	100	92	100	89	92	92	72	72	72	83	92	
OVERALL COMPLIANCE FOR 2023/2024														88