

Test Report

Page 1 of 1

Client: Witzenberg Municipality
Address: 50 Voortrekker Street, Ceres, 6835
Report no: 223761
Project: Witzenberg Drinking Water

Date of report: 06 June 2025
Date accepted: 04 June 2025
Date completed: 06 June 2025
Date received: 04 June 2025

Lab no:					Uncertainty of measure- ment %	SANS 241- 1:2015	261040	
Date sampled:							04-Jun-25	
Aquatico sampled:							Yes	
Sample type:							Water	
Locality description:							Wolseley Water Treatment Works Final	
Analyses				Unit	Method			
A	AQCL	E.coli		CFU/100ml	ALM 40	7.74	0	<1
A	AQCL	Total coliform		CFU/100ml	ALM 40	7.76	< 10	<1
A	AQCL	Heterotrophic plate count		CFU/ml	ALM 45	2.22	< 1000	3

A = Accredited N = Not accredited Sub = Sub-contracted NR = Not requested RTF = Results to follow NATD = Not able to determine ATR = Alternative test report ; Results relate only to the items sampled and tested ; Results reported against the limit of detection; Results marked "Not SANAS Accredited" in this report are not covered by the Scope of Accreditation for this laboratory; Uncertainty of measurement available on request for all methods included in the SANAS Schedule of Accreditation; The report shall not be reproduced except in full without approval of the laboratory

AQL = Aquatico Laboratories ; AQCL = Aquatico Cape Laboratories