

Test Report

Page 1 of 2

Client: Witzenberg Municipality
Address: 50 Voortrekker Street, Ceres, 6835
Report no: 220297
Project: Witzenberg Drinking Water

Date of report: 13 May 2025
Date accepted: 06 May 2025
Date completed: 13 May 2025
Date received: 06 May 2025

Lab no:					Uncertainty of measure- ment %	SANS 241- 1:2015	244883	
Date sampled:							05-May-25	
Aquatico sampled:							Yes	
Sample type:							Water	
Locality description:							Wolseley Water Treatment Works Final	
Analyses				Unit	Method			
A	AQCL	pH @ 25°C		pH	ALM 20	2.33	5 - 9.7	6.69
A	AQCL	Electrical conductivity (EC) @ 25°C		mS/m	ALM 20	4.92	< 170	3.14
A	AQCL	Total Dissolved solids @ 180°C		mg/l	ALM 24	9.42	< 1200	22
A	AQCL	Chloride (Cl)		mg/l	ALM 02	7.57	< 300	2.55
A	AQCL	Nitrate (NO ₃) as N		mg/l	ALM 06	9.46	< 11	<0.194
A	AQCL	Total oxidised nitrogen as N		mg/l	ALM 06	9.46		<0.194
A	AQCL	Nitrite (NO ₂) as N		mg/l	ALM 07	7.73	< 0.9	<0.065
A	AQCL	Ammonium (NH ₄) as N		mg/l	ALM 05	8.46	< 1.5	0.095
N	AQCL	Un-ionized Ammonia as N		mg/l	ALM 26			<0.005
A	AQCL	Fluoride (F)		mg/l	ALM 08	9.76	< 1.5	<0.263
A	AQCL	Acid Soluble Aluminium (Al)		mg/l	ALMA 31	7.08	< 0.3	0.025
A	AQCL	Acid Soluble Iron (Fe)		mg/l	ALMA 31	7.16	< 0.3	0.013
A	AQCL	Acid Soluble Manganese (Mn)		mg/l	ALMA 31	6.34	< 0.1	0.005
A	AQCL	Acid Soluble Copper (Cu)		mg/l	ALMA 31	5.15	< 2	0.004
A	AQCL	E.coli		CFU/100ml	ALM 40	7.74	0	<1
A	AQCL	Total coliform		CFU/100ml	ALM 40	7.76	< 10	1
A	AQCL	Heterotrophic plate count		CFU/ml	ALM 45	2.22	< 1000	33
A	AQCL	Turbidity		NTU	ALM 21	5.9	< 1	0.685
N	AQCL	Total Chlorine (Cl ₂)		mg/l	ALM 23	5.94		0.07
A	AQCL	Free chlorine (Cl ₂)		mg/l	ALM 23	5.94	< 5	0.02
A	AQCL	True Colour		mg/l Pt-Co	ALM 22	8.74	< 15	<5.00
A	AQL	Total organic carbon (TOC)		mg/l	ALM 63	6.46	< 10	1.57
A	AQCL	Temperature		°C	ALM 20			21.7
N	AQL	Nitrate + Nitrite as N		mg/l	ALM 26			0.147
A	AQCL	Nitrite as NO ₂		mg/l	ALM 26			<0.020

A = Accredited N = Non accredited Sub = Sub-contracted NR = Not requested RTF = Results to follow NATD = Not able to determine ATR = Alternative test report ; Results relate only to the items sampled and tested ; Results reported against the limit of detection; Results marked 'Non SANAS Accredited' in this report are not included in the SANAS Schedule of Accreditation for this laboratory; Uncertainty of measurement available on request for all methods included in the SANAS Schedule of Accreditation; The report shall not be reproduced except in full without approval of the laboratory

AQL = Aquatigo Laboratories ; AQCL = Aquatigo Cape Laboratories

Test Report

Page 2 of 2

Client: Witzenberg Municipality
Address: 50 Voortrekker Street, Ceres, 6835
Report no: 220297
Project: Witzenberg Drinking Water

Date of report: 13 May 2025
Date accepted: 06 May 2025
Date completed: 13 May 2025
Date received: 06 May 2025

Lab no:					Uncertainty of measure- ment %	SANS 241- 1:2015	244883
Date sampled:							05-May-25
Aquatico sampled:							Yes
Sample type:							Water
Locality description:							Wolseley Water Treatment Works Final
Analyses				Unit	Method		
A	AQCL	Nitrate as NO ₃	mg/l	ALM 26			<0.859
A	AQL	Trihalomethanes (THM)	µg/l	OLM 02	12.24		<2
A	AQL	Bromoform	µg/l	OLM 02	11.28	< 100	<2
A	AQL	Chloroform	µg/l	OLM 02	13.73	< 300	<2
A	AQL	Dibromochloromethane	µg/l	OLM 02	11.83	< 100	<2
A	AQL	Bromodichloromethane	µg/l	OLM 02	12.11	< 60	<2
A	AQL	Combined Bromoform	ratio	OLM 02			<0.020
A	AQL	Combined Chloroform	ratio	OLM 02			<0.007
A	AQL	Combined Dibromochloromethane	ratio	OLM 02			<0.020
A	AQL	Combined Bromodichloromethane	ratio	OLM 02			<0.033
A	AQL	THM Sum of rations	ratio	OLM 02		< 1	<0.080
N	AQL	Combined Nitrate plus Nitrite	ratio	ALM 26		< 1	<1.00
A	AQCL	Free and Saline Ammonia as N	mg/l	ALM 26			0.095

A = Accredited N = Non accredited Sub = Sub-contracted NR = Not requested RTF = Results to follow NATD = Not able to determine ATR = Alternative test report ; Results relate only to the items sampled and tested ; Results reported against the limit of detection; Results marked 'Non SANAS Accredited' in this report are not included in the SANAS Schedule of Accreditation for this laboratory; Uncertainty of measurement available on request for all methods included in the SANAS Schedule of Accreditation; The report shall not be reproduced except in full without approval of the laboratory

Authenticated signature on first page

AQL = Aquatico Laboratories ; AQCL = Aquatico Cape Laboratories